

Richard Smith
Planning Officer
The Moray Council
Development Services
Council Office
High Street
Elgin, IV30 1BX



Ashgrove Road West
Aberdeen
AB16 5NY

Telephone 01224 667270
(direct line)
Facsimile: 01224 667388

Date 12 June 2009

Our Reference: plan62/09/GG
Your Reference: 09/00247/FUL

Dear Richard,

Planning Application, Two Wind Turbines Myreton Crossroads - Keith

I refer to your letter dated 10 June 2009 in connection with the above.

We would have no issues with regard to the wind farm development, as all of the turbines are located greater than 1.5 x falling distance from our existing overhead line network.

Should you have any queries in connection with the above, please do not hesitate to contact me.

Yours sincerely



Graeme Gill
Senior Wayleave Officer,
North East District.



This copy has been made by the authority of Scottish Power Energy Networks Limited (SPENL) under the provisions of the Copyright, Designs and Patents Act 1988. It is provided as a reference only and does not constitute an offer of any service. No liability is accepted for any loss or damage arising from the use of this information. For more information, please contact the copyright owner.

SPENL is a member of the Scottish Power Group. SPENL is a subsidiary of Scottish Power Energy Networks Limited. SPENL is a member of the Scottish Power Group. SPENL is a subsidiary of Scottish Power Energy Networks Limited.

Scottish Water Services (SWS) is a subsidiary of Scottish Water. SWS is a member of the Scottish Water Group. SWS is a subsidiary of Scottish Water.

Registered Office: Metropolitan House, 200 North Street, Glasgow G1 3JF, Scotland.

NORTH EAST DISTRICT

Tel: 01224 667200

All Voltages

Scale : 1:10000

12/06/2009

NJ50475670

UNCONTROLLED COPY
Subject to revision without notice.

NORMAL DEPTH TO THE TOP OF THE
CABLE WHEN LAID.

FOOTPATH 0.40m 0.45m 0.60m 0.75m
ROAD CROSSING 0.65m 0.68m 0.75m 0.90m

i.v./services - upto 1000V
h.v. - over 1000V to 11,000V
e.h.v. - 22,000V and 132,000V

WARNING

There may have been subsequent alterations to the network since this map was produced. It is the user's responsibility to ensure that the information shown on this map is up to date. The user should consult the appropriate authority for the latest information. The user should also be aware that the information shown on this map is for reference only and does not constitute an offer of any service. No liability is accepted for any loss or damage arising from the use of this information.

(Sourced from SPENL)

For plots at 1:10000 scale there may be more information visible at 1:500 scale. Responsibility is with the user of this map to check to further information exists at 1:500 scale.

