

15/07/2013

Moray Council
Development Services Environment Services
High Street
Elgin
IV30 1BX

SCOTTISH WATER

Customer Connections
419 Balmore Road
Glasgow
G22 6NU

Customer Support Team
T: 0141 355 5511
F: 0141 355 5386
W: www.scottishwater.co.uk
E: connections@scottishwater.co.uk

Dear Sir Madam

PLANNING APPLICATION NUMBER: 13/00188/APP
DEVELOPMENT: Elgin, Mosstowie, Moorside
OUR REFERENCE: 629388
PROPOSAL: Erect House

Please quote our reference in all future correspondence

Scottish Water has no objection to this planning application. This response is made based on the information available to us at this time and does not guarantee a connection to Scottish Water's infrastructure. A separate application should be submitted to us made for connection to our infrastructure after full planning has been granted.

GLENLATTERACH Water Treatment Works – has limited capacity available for new demand. The Developer should discuss their development directly with Scottish Water.

In some circumstances it may be necessary for the Developer to fund works on existing infrastructure to enable their development to connect. Should we become aware of any issues such as flooding, low pressure, etc the Developer will be required to fund works to mitigate the effect of the development on existing customers. Scottish Water can make a contribution to these costs through Reasonable Cost funding rules.

A totally separate drainage system will be required with the surface water discharging to a suitable outlet. Scottish Water requires a sustainable urban drainage system (SUDS) as detailed in Sewers for Scotland 2 if the system is to be considered for adoption.

Scottish Water's current minimum level of service for water pressure is 1.0 bar or 10m head at the customer's boundary internal outlet. Any property which cannot be adequately serviced from the available pressure may require private pumping arrangements installed, subject to compliance with the current water byelaws. If the developer wishes to enquire about Scottish Water's procedure for checking the water pressure in the area then they should write to the Customer Connections department at the above address.

If the connection to public sewer and/or water main requires to be laid through land out-with public ownership, the developer must provide evidence of formal approval from the affected landowner(s). This should be done through a deed of servitude.

Should the developer require information regarding the location of Scottish Water infrastructure they should contact our Property Searches Department, Bullion House, Dundee, DD2 5BB. Tel – 0845 601 8855.

further representation - scottish water

If the developer requires any further assistance or information on our response, please contact me on the above number or alternatively additional information is available on our website:
www.scottishwater.co.uk.

Yours faithfully

Janine Franssen
Customer Connections Administrator